

**TECHNICAL REVIEW COMMITTEE NOTES
SERVEPRO OF THE SEACOAST INC.
29 INDUSTRIAL PARK DR (P08-36)
THURSDAY OCTOBER 2, 2008**

PRESENT: Christopher Parker, Dave White, Tom Clark

OTHERS: Doug LaRosa, Matt Salvacci, Jim Och, Linda Merullo

Planning

1. Add the plan number (P08-36) to the cover sheet/title block.
2. Label the dumpster pad.
3. Show the traffic flow area. Note that it's a 2 way.
4. Present a copy of the signed shared driveway agreement.
5. Update the intent note including the amount of paved square footage being added.

Engineering

1. Add a 5 ft. grass strip to separate the driveway from the parking lot.
2. Elongate the NW detention area.

Fire Dept.

1. Mark the "Fire Lane" by adding a stripe and sign.

Building Inspection

1. Add 1 Handicap parking space with a sign and markings.

Clark made the motion, for the plans, to not go before the Planning Board, White seconded. Vote: U/A